



75 Suttle Street  
Durango, CO 81303  
970.247.4220 Phone  
970.247.4227 Fax  
[www.greenanalytical.com](http://www.greenanalytical.com)

11 February 2020

Mike Lancianese  
Edgemont Ranch  
5972 CR 234  
Durango, CO 81301  
RE: THM/HAA

Enclosed are the results of analyses for samples received by the laboratory on 01/23/20 11:30. The data to follow was performed, in whole or in part, by a subcontract laboratory with an additional report attached.

If you need any further assistance, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads 'Debbie Zufelt'.

Debbie Zufelt  
Reports Manager

All accredited analytes contained in this report are denoted by an asterisk (\*). For a complete list of accredited analytes please do not hesitate to contact us via any of the contact information contained in this report. All of our certifications can be viewed at <http://greenanalytical.com/certifications/>

Green Analytical Laboratories is NELAP accredited through the Texas Commission on Environmental Quality. Accreditation applies to drinking water and non-potable water matrices for trace metals and a variety of inorganic parameters. Green Analytical Laboratories is also accredited through the Colorado Department of Public Health and Environment and EPA region 8 for trace metals, Cyanide, Fluoride, Nitrate, and Nitrite in drinking water.

Our affiliate laboratory, Cardinal Laboratories, is also NELAP accredited through the Texas Commission on Environmental Quality for a variety of organic constituents in drinking water, non-potable water and solid matrices. Cardinal is also accredited for regulated VOCs, TTHM, and HAA-5 in drinking water through the Colorado Department of Public Health and Environment and EPA region 8.



Edgemont Ranch	Project: THM/HAA	
5972 CR 234	Project Name / Number: CO0134200	<b>Reported:</b>
Durango CO, 81301	Project Manager: Mike Lancianese	02/11/20 10:36

**ANALYTICAL REPORT FOR SAMPLES**

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received	Notes
Max Res 1, Community Center DBP001	2001193-01	Water	01/23/20 10:45	01/23/20 11:30	
TB	2001193-02	Water	01/23/20 00:00	01/23/20 11:30	

Green Analytical Laboratories

Debbie Zufelt, Reports Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. In no event shall Green Analytical Laboratories be liable for incidental or consequential damages. GALs liability, and clients exclusive remedy for any claim arising, shall be limited to the amount paid by client for analyses. All claims, including those for negligence and any other cause whatsoever, shall be deemed waived unless made in writing and received within thirty days after completion of the applicable service.



Edgemont Ranch 5972 CR 234 Durango CO, 81301	Project: THM/HAA Project Name / Number: CO0134200 Project Manager: Mike Lancianese	Reported: 02/11/20 10:36
--	--	-----------------------------

**Max Res 1, Community Center DBP001**

**2001193-01 (Surface Water)**

Analyte	Result	RL	MDL	Units	Dilution	Analyzed	Method	Notes	Analyst
---------	--------	----	-----	-------	----------	----------	--------	-------	---------

Subcontracted -- Cardinal Laboratories

**Haloacetic Acids by GC/ECD**

Monochloroacetic Acid*	<1.0	1.0	0.8	ug/L	1	02/05/20 23:41	552.2		CK/
Monobromoacetic Acid*	<1.0	1.0	0.2	ug/L	1	02/05/20 23:41	552.2		CK/
Dichloroacetic Acid*	5.7	1.0	0.3	ug/L	1	02/05/20 23:41	552.2		CK/
Trichloroacetic Acid*	2.3	1.0	0.3	ug/L	1	02/05/20 23:41	552.2		CK/
Dibromoacetic Acid*	3.4	1.0	0.2	ug/L	1	02/05/20 23:41	552.2		CK/
Total HAA5s*	11.4	1.0		ug/L	1	02/05/20 23:41	552.2		CK/
Surrogate: 2,3-Dibromopropionic Acid			77.3 %	70-130		02/05/20 23:41	552.2		CK/

**VOLATILES BY GC/MS**

Chloroform	7.28	0.500	0.142	ug/L	1	02/03/20 20:41	524.2		ms
Bromodichloromethane	9.85	0.500	0.140	ug/L	1	02/03/20 20:41	524.2		ms
Dibromochloromethane	10.2	0.500	0.111	ug/L	1	02/03/20 20:41	524.2		ms
Bromoform	2.26	0.500	0.242	ug/L	1	02/03/20 20:41	524.2		ms
TTHMs*	29.6	0.500		ug/L	1	02/03/20 20:41	524.2		ms
Surrogate: Dibromofluoromethane			108 %	70-130		02/03/20 20:41	524.2		ms
Surrogate: Toluene-d8			97.2 %	70-130		02/03/20 20:41	524.2		ms
Surrogate: 4-Bromofluorobenzene			97.7 %	70-130		02/03/20 20:41	524.2		ms

Green Analytical Laboratories

Debbie Zufelt, Reports Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. In no event shall Green Analytical Laboratories be liable for incidental or consequential damages. GALs liability, and clients exclusive remedy for any claim arising, shall be limited to the amount paid by client for analyses. All claims, including those for negligence and any other cause whatsoever, shall be deemed waived unless made in writing and received within thirty days after completion of the applicable service.



Edgemont Ranch 5972 CR 234 Durango CO, 81301	Project: THM/HAA Project Name / Number: CO0134200 Project Manager: Mike Lancianese	Reported: 02/11/20 10:36
--	--	-----------------------------

**TB**

**2001193-02 (Water)**

Analyte	Result	RL	MDL	Units	Dilution	Analyzed	Method	Notes	Analyst
---------	--------	----	-----	-------	----------	----------	--------	-------	---------

Subcontracted -- Cardinal Laboratories

**VOLATILES BY GC/MS**

<b>Chloroform</b>	<0.500	0.500	0.142	ug/L	1	02/03/20 21:04	524.2		ms
<b>Bromodichloromethane</b>	<0.500	0.500	0.140	ug/L	1	02/03/20 21:04	524.2		ms
<b>Dibromochloromethane</b>	<0.500	0.500	0.111	ug/L	1	02/03/20 21:04	524.2		ms
<b>Bromoform</b>	<0.500	0.500	0.242	ug/L	1	02/03/20 21:04	524.2		ms
<b>TTHMs*</b>	<0.500	0.500		ug/L	1	02/03/20 21:04	524.2		ms
<i>Surrogate: Dibromofluoromethane</i>			107 %	70-130		02/03/20 21:04	524.2		ms
<i>Surrogate: Toluene-d8</i>			96.9 %	70-130		02/03/20 21:04	524.2		ms
<i>Surrogate: 4-Bromofluorobenzene</i>			98.2 %	70-130		02/03/20 21:04	524.2		ms

Green Analytical Laboratories

Debbie Zufelt, Reports Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. In no event shall Green Analytical Laboratories be liable for incidental or consequential damages. GALs liability, and clients exclusive remedy for any claim arising, shall be limited to the amount paid by client for analyses. All claims, including those for negligence and any other cause whatsoever, shall be deemed waived unless made in writing and received within thirty days after completion of the applicable service.



Edgemont Ranch 5972 CR 234 Durango CO, 81301	Project: THM/HAA Project Name / Number: CO0134200 Project Manager: Mike Lancianese	Reported: 02/11/20 10:36
--	--	-----------------------------

**Haloacetic Acids by GC/ECD - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

**Batch 0013003 - Solvent Extraction**

**Blank (0013003-BLK1)**

Prepared & Analyzed: 02/05/20

<i>Surrogate: 2,3-Dibromopropionic Acid</i>	3.55		ug/L	5.00		71.0	70-130			
Dibromoacetic Acid	ND	1.0	ug/L							
Dichloroacetic Acid	ND	1.0	ug/L							
Monobromoacetic Acid	ND	1.0	ug/L							
Monochloroacetic Acid	ND	1.0	ug/L							
Total HAA5s	ND	1.0	ug/L							
Trichloroacetic Acid	ND	1.0	ug/L							

**LCS (0013003-BS1)**

Prepared & Analyzed: 02/05/20

<i>Surrogate: 2,3-Dibromopropionic Acid</i>	3.76		ug/L	5.00		75.2	70-130			
Dibromoacetic Acid	17.6	1.0	ug/L	20.0		87.9	70-130			
Dichloroacetic Acid	19.1	1.0	ug/L	20.0		95.3	70-130			
Monobromoacetic Acid	19.6	1.0	ug/L	20.0		97.8	70-130			
Monochloroacetic Acid	20.9	1.0	ug/L	20.0		104	70-130			
Total HAA5s	93.1	1.0	ug/L	100		93.1	70-130			
Trichloroacetic Acid	16.0	1.0	ug/L	20.0		80.0	70-130			

**LCS Dup (0013003-BSD1)**

Prepared & Analyzed: 02/05/20

<i>Surrogate: 2,3-Dibromopropionic Acid</i>	3.27		ug/L	5.00		65.3	70-130			S-04
Dibromoacetic Acid	15.9	1.0	ug/L	20.0		79.4	70-130	10.2	20	
Dichloroacetic Acid	18.3	1.0	ug/L	20.0		91.3	70-130	4.32	20	
Monobromoacetic Acid	18.7	1.0	ug/L	20.0		93.6	70-130	4.38	20	
Monochloroacetic Acid	20.7	1.0	ug/L	20.0		104	70-130	0.856	20	
Total HAA5s	88.9	1.0	ug/L	100		88.9	70-130	4.56	20	
Trichloroacetic Acid	15.4	1.0	ug/L	20.0		76.9	70-130	3.94	20	

Green Analytical Laboratories

Debbie Zufelt, Reports Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. In no event shall Green Analytical Laboratories be liable for incidental or consequential damages. GALs liability, and clients exclusive remedy for any claim arising, shall be limited to the amount paid by client for analyses. All claims, including those for negligence and any other cause whatsoever, shall be deemed waived unless made in writing and received within thirty days after completion of the applicable service.



Edgemont Ranch 5972 CR 234 Durango CO, 81301	Project: THM/HAA Project Name / Number: CO0134200 Project Manager: Mike Lancianese	Reported: 02/11/20 10:36
--	--	-----------------------------

**VOLATILES BY GC/MS - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

**Batch 0013104 - Volatiles**

**Blank (0013104-BLK1)**

Prepared: 01/31/20 Analyzed: 02/03/20

Surrogate: 4-Bromofluorobenzene	24.3		ug/L	25.0		97.3	70-130			
Bromodichloromethane	ND	0.500	ug/L							
Bromoform	ND	0.500	ug/L							
Chloroform	ND	0.500	ug/L							
Dibromochloromethane	ND	0.500	ug/L							
Surrogate: Dibromofluoromethane	26.3		ug/L	25.0		105	70-130			
Surrogate: Toluene-d8	24.5		ug/L	25.0		98.1	70-130			
TTHMs	ND	0.500	ug/L							

**LCS (0013104-BS1)**

Prepared: 01/31/20 Analyzed: 02/03/20

Surrogate: 4-Bromofluorobenzene	26.0		ug/L	25.0		104	70-130			
Bromodichloromethane	20.2	0.500	ug/L	20.0		101	70-130			
Bromoform	21.3	0.500	ug/L	20.0		107	70-130			
Chloroform	20.0	0.500	ug/L	20.0		99.9	70-130			
Dibromochloromethane	19.9	0.500	ug/L	20.0		99.4	70-130			
Surrogate: Dibromofluoromethane	25.5		ug/L	25.0		102	70-130			
Surrogate: Toluene-d8	24.4		ug/L	25.0		97.5	70-130			
TTHMs	81.4	0.500	ug/L	80.0		102	70-130			

**LCS Dup (0013104-BSD1)**

Prepared: 01/31/20 Analyzed: 02/03/20

Surrogate: 4-Bromofluorobenzene	26.6		ug/L	25.0		107	70-130			
Bromodichloromethane	19.8	0.500	ug/L	20.0		99.2	70-130	1.65	20	
Bromoform	18.4	0.500	ug/L	20.0		92.2	70-130	14.5	20	
Chloroform	19.9	0.500	ug/L	20.0		99.6	70-130	0.251	20	
Dibromochloromethane	18.6	0.500	ug/L	20.0		93.2	70-130	6.38	20	
Surrogate: Dibromofluoromethane	25.9		ug/L	25.0		104	70-130			
Surrogate: Toluene-d8	24.6		ug/L	25.0		98.4	70-130			
TTHMs	76.9	0.500	ug/L	80.0		96.1	70-130	5.69	20	

Green Analytical Laboratories

*Debbie Zufelt*

Debbie Zufelt, Reports Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. In no event shall Green Analytical Laboratories be liable for incidental or consequential damages. GALs liability, and clients exclusive remedy for any claim arising, shall be limited to the amount paid by client for analyses. All claims, including those for negligence and any other cause whatsoever, shall be deemed waived unless made in writing and received within thirty days after completion of the applicable service.



Edgemont Ranch  
5972 CR 234  
Durango CO, 81301

Project: THM/HAA  
Project Name / Number: CO0134200  
Project Manager: Mike Lancianese

Reported:  
02/11/20 10:36

Notes and Definitions

- S-04 The surrogate recovery for this sample is outside of established control limits due to a sample matrix effect.
- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the reporting limit
- NR Not Reported
- dry Sample results reported on a dry weight basis  
\*Results reported on as received basis unless designated as dry.
- RPD Relative Percent Difference
- LCS Laboratory Control Sample (Blank Spike)
- RL Report Limit
- MDL Method Detection Limit

Green Analytical Laboratories

Debbie Zufelt, Reports Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. In no event shall Green Analytical Laboratories be liable for incidental or consequential damages. GALs liability, and clients exclusive remedy for any claim arising, shall be limited to the amount paid by client for analyses. All claims, including those for negligence and any other cause whatsoever, shall be deemed waived unless made in writing and received within thirty days after completion of the applicable service.



**GREEN Analytical Laboratories**

(970) 247-4220  
 Fax: (970) 247-4227

Jenna.emerick@greenanalytical.com or  
 dzulett@greenanalytical.com  
 75 Suttle St Durango, CO 81303

**CHAIN-OF-CUSTODY AND ANALYSIS REQUEST**

FORM-006  
 COC - Revision 6.0

Company or Client: Edgemont Ranch Metro District  
 Address: 5972 CR. 234 State: CO Zip: 81301  
 City: Durango  
 Phone #: 970-749-1485  
 Contact Person: MIKE LANCIANESI  
 Email Report to: MIKE@EDGEMONTRANCH.COM  
 Project Name(optional): 1ST QUARTER TMM/HAS SAMPLES  
 Sampler Name (Print): \_\_\_\_\_

P.O. #: \_\_\_\_\_  
 Company: \_\_\_\_\_  
 Attn: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 City: \_\_\_\_\_  
 State: \_\_\_\_\_ Zip: \_\_\_\_\_  
 Phone #: \_\_\_\_\_  
 Email: \_\_\_\_\_

Bill to (if different): \_\_\_\_\_

For Lab Use	Sample Name or Location	Collected		Matrix (check one)						# of containers					ANALYSIS REQUEST				
		Date	Time	GROUNDWATER	SURFACEWATER	WASTEWATER	PRODUCEDWATER	SOIL	DRINKING WATER	OTHER :	No preservation (general)	HNO <sub>3</sub>	HCl	H <sub>2</sub> SO <sub>4</sub>	Other:	Other:			
	2001-193-01 MAX RES 1, Community Center	1/23/20	1045AM		X														
	-01-01 MAX RES 1, Community Center	1/23/20	1045AM		X														
	-02-05 T. B.																		

PLEASE NOTE: GAL's liability and client's exclusive remedy for any claim arising whether based in contract or tort, shall be limited to the amount paid by the client for the analyses. All claims including those for negligence and any other cause whatsoever shall be deemed waived unless made in writing and received by GAL within 30 days after completion. In no event shall GAL be liable for incidental or consequential damages, including without limitation, business interruptions, loss of use, or loss of profits incurred by client, its subsidiaries, affiliates or successors arising out of or related to the performance of services hereunder by GAL, regardless of whether such claim is based upon any of the above stated reasons or otherwise.

Relinquished By: [Signature] Date: 1/23/20 Time: 11:30 AM  
 Received By: [Signature]  
 Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Received By: \_\_\_\_\_  
 Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Received By: \_\_\_\_\_

ADDITIONAL REMARKS: 33/31c #1 onlv  
 Temperature at receipt: 33/31c CHECKED BY: [Signature]

Report to State? (Circle)  
 Yes  No

\* GAL cannot always accept verbal changes. Please fax or email written change requests.  
 \* Chain of Custody must be signed in "Relinquished By:" as an acceptance of services and all applicable charges.





Colorado Department of Public Health and Environment

Total Trihalomethane Certified Laboratory Report Form  
WQCD - Drinking Water CAS  
4300 Cherry Creek Drive South, Denver, CO 80246-1530  
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revision: 6/13/2014

**TTHM**

Section I (Supplied or Completed by Public Water System)

Public Water System Information

PWS ID: CO 0134200 Facility ID: DS001

System Name: EGGEMONT RIVER METRO DISTRICT

Contact Person: MIKE LANCIANESI Phone #: 970-749-1485

Comments: 1st Quarter Samples

Section II (Supplied or Completed by Certified Laboratory)

Certified Laboratory Information

Laboratory ID:

Laboratory Name:

Contact Person:

Comments:

Section III (Supplied or Completed by PWS)

Sample Date: 1/23/20 Sample Pt ID: DBP 001 Address - Location: MAX RES 1 COMMUNITY CENTER

Section IV (Supplied or Completed by Certified Laboratory)

Sample Date	Sample Pt ID	Address - Location	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte (code)	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
						Chloroform (2941)		N/A		
						Bromoform (2942)		N/A		
						Bromodichloromethane (2943)		N/A		
						Dibromochloromethane (2944)		N/A		
						TTHMs (2950)		80	N/A	
						Chloroform (2941)		N/A		
						Bromoform (2942)		N/A		
						Bromodichloromethane (2943)		N/A		
						Dibromochloromethane (2944)		N/A		
						TTHMs (2950)		80	N/A	
						Chloroform (2941)		N/A		
						Bromoform (2942)		N/A		
						Bromodichloromethane (2943)		N/A		
						Dibromochloromethane (2944)		N/A		
						TTHMs (2950)		80	N/A	
						Chloroform (2941)		N/A		
						Bromoform (2942)		N/A		
						Bromodichloromethane (2943)		N/A		
						Dibromochloromethane (2944)		N/A		
						TTHMs (2950)		80	N/A	
						Chloroform (2941)		N/A		
						Bromoform (2942)		N/A		
						Bromodichloromethane (2943)		N/A		
						Dibromochloromethane (2944)		N/A		
						TTHMs (2950)		80	N/A	

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than sign (<) may also be used

ug/L: Micrograms per Liter

MCL: Maximum Contaminant Level



Colorado Department  
of Public Health  
and Environment

**Haloacetic Acids Certified Laboratory Report Form**  
WQCD – Drinking Water CAS  
4300 Cherry Creek Drive South; Denver, CO 80246-1530  
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revision: 6/13/2014

**HAA5**

Section I (Supplied or Completed by Public Water System)			Section II (Supplied or Completed by Certified Laboratory)							
Public Water System Information			Certified Laboratory Information							
PWS ID: <i>CO 0134200</i>	Facility ID: DS001	Laboratory ID:								
System Name: <i>EDGEMONT RANCH METRO DISTRICT</i>		Laboratory Name:								
Contact Person: <i>MIKE LANGRANSE</i>	Phone #: <i>970-749-1485</i>	Contact Person:					Phone #:			
Comments: <i>1<sup>st</sup> QUARTER SAMPLES</i>			Comments:							
Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte (code)	Analytical Method	Lab MRL (ug/L)	Result (ug/L)	
<i>1/23/20</i>	<i>DBP 001</i>	<i>MAX RES 1 COMMUNITY CENTER</i>				Monochlo. Acid (2450)		N/A		
						Monobro. Acid (2453)		N/A		
						Dichlor. Acid (2451)		N/A		
						Trichlor. Acid (2452)		N/A		
						Dibromo. Acid (2454)		N/A		
						HAA5s (2456)	N/A	60	N/A	
	<i>DBP</i>					Monochlo. Acid (2450)		N/A		
						Monobro. Acid (2453)		N/A		
						Dichlor. Acid (2451)		N/A		
						Trichlor. Acid (2452)		N/A		
						Dibromo. Acid (2454)		N/A		
						HAA5s (2456)	N/A	60	N/A	
	<i>DBP</i>					Monochlo. Acid (2450)		N/A		
						Monobro. Acid (2453)		N/A		
						Dichlor. Acid (2451)		N/A		
						Trichlor. Acid (2452)		N/A		
						Dibromo. Acid (2454)		N/A		
						HAA5s (2456)	N/A	60	N/A	
	<i>DBP</i>					Monochlo. Acid (2450)		N/A		
						Monobro. Acid (2453)		N/A		
						Dichlor. Acid (2451)		N/A		
						Trichlor. Acid (2452)		N/A		
						Dibromo. Acid (2454)		N/A		
						HAA5s (2456)	N/A	60	N/A	

NT: Not Tested  
MCL: Maximum Contaminant Level

ug/L: Micrograms per Liter  
BDL: Below Laboratory MRL. A less than sign (<) may also be used



Colorado Department  
of Public Health  
and Environment

# Haloacetic Acids Certified Laboratory Report Form

WQCD – Drinking Water CAS

4300 Cherry Creek Drive South; Denver, CO 80246-1530

Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revision: 6/13/2014

## HAA5

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWS ID: CO0134200	Facility ID: DS001	Laboratory ID: H000240 AUTOLOG FROM GAL 2001-193	
System Name: EDGEMONT RANCH METRO DISTRICT		Laboratory Name: CARDINAL LABORATORIES	
Contact Person: MIKE LANCIANESE	Phone #: 970-749-1485	Contact Person: CELEY KEENE	Phone #: 575-393-2326
Comments: 1ST QUARTER SAMPLES		Comments:	

Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID <i>On Schedule</i>	Address – Location	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte (code)	Analytical Method		Lab MRL (ug/L)	Result (ug/L)
01/23/20	DBP 001	MAXRES 1 COMMUNITY CENTER	01/24/20	02/05/20	H000240-01	Monochlo. Acid (2450)	EPA 552.2	N/A	1.0	<1.0
						Monobro. Acid (2453)	EPA 552.2	N/A	1.0	<1.0
						Dichlor. Acid (2451)	EPA 552.2	N/A	1.0	5.7
						Trichlor. Acid (2452)	EPA 552.2	N/A	1.0	2.3
						Dibromo. Acid (2454)	EPA 552.2	N/A	1.0	3.4
						HAA5s (2456)	N/A	60	N/A	11.4
	DBP					Monochlo. Acid (2450)	EPA 552.2	N/A	1.0	
						Monobro. Acid (2453)	EPA 552.2	N/A	1.0	
						Dichlor. Acid (2451)	EPA 552.2	N/A	1.0	
						Trichlor. Acid (2452)	EPA 552.2	N/A	1.0	
						Dibromo. Acid (2454)	EPA 552.2	N/A	1.0	
						HAA5s (2456)	N/A	60	N/A	
	DBP					Monochlo. Acid (2450)		N/A		
						Monobro. Acid (2453)		N/A		
						Dichlor. Acid (2451)		N/A		
						Trichlor. Acid (2452)		N/A		
						Dibromo. Acid (2454)		N/A		
						HAA5s (2456)	N/A	60	N/A	
	DBP					Monochlo. Acid (2450)		N/A		
						Monobro. Acid (2453)		N/A		
						Dichlor. Acid (2451)		N/A		
						Trichlor. Acid (2452)		N/A		
						Dibromo. Acid (2454)		N/A		
						HAA5s (2456)	N/A	60	N/A	

NT: Not Tested

MCL: Maximum Contaminant Level

ug/L: Micrograms per Liter

BDL: Below

Lab MRL: Laboratory Minimum Reporting Level



# Total Trihalomethane Certified Laboratory Report Form

Revision: 6/13/2014

WQCD – Drinking Water CAS

4300 Cherry Creek Drive South; Denver, CO 80246-1530

Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

## TTHM

Colorado Department  
of Public Health  
and Environment

Section I (Supplied or Completed by Public Water System)			Section II (Supplied or Completed by Certified Laboratory)		
Public Water System Information			Certified Laboratory Information		
PWS ID:	CO0134200	Facility ID: DS001	Laboratory ID:	H000240 AUTOLOG FROM GAL 2001-193	
System Name:	EDGEMONT RANCH METRO DISTRICT		Laboratory Name:	CARDINAL LABORATORIES	
Contact Person:	MIKE LANCIANESE	Phone #: 970-749-1485	Contact Person:	CELEY KEENE	Phone #: 575-393-2326
Comments:	1ST QUARTER SAMPLES		Comments:		

Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID <i>On Schedule</i>	Address – Location	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte (code)	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
01/23/20	DBP 001	MAXRES 1 COMMUNITY CENTER	01/24/20	02/03/20	H000240-01	Chloroform (2941)	EPA 524.2	N/A	0.5	7.28
						Bromoform (2942)	EPA 524.2	N/A	0.5	2.26
						Bromodichloromethane (2943)	EPA 524.2	N/A	0.5	9.85
						Dibromochloromethane (2944)	EPA 524.2	N/A	0.5	10.2
						TTHMs (2950)	N/A	80	N/A	29.6
01/23/20	DBP TRIP BLANK	N/A	01/24/20	02/03/20	H000240-02	Chloroform (2941)	EPA 524.2	N/A	0.5	<0.5
						Bromoform (2942)	EPA 524.2	N/A	0.5	<0.5
						Bromodichloromethane (2943)	EPA 524.2	N/A	0.5	<0.5
						Dibromochloromethane (2944)	EPA 524.2	N/A	0.5	<0.5
						TTHMs (2950)	N/A	80	N/A	<0.5
	DBP					Chloroform (2941)	EPA 524.2	N/A	0.5	
						Bromoform (2942)	EPA 524.2	N/A	0.5	
						Bromodichloromethane (2943)	EPA 524.2	N/A	0.5	
						Dibromochloromethane (2944)	EPA 524.2	N/A	0.5	
						TTHMs (2950)	N/A	80	N/A	
	DBP					Chloroform (2941)		N/A		
						Bromoform (2942)		N/A		
						Bromodichloromethane (2943)		N/A		
						Dibromochloromethane (2944)		N/A		
						TTHMs (2950)	N/A	80	N/A	

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than sign (<) may also be

ug/L: Micrograms per Liter

MCL: Maximum Contaminant Level