



METROPOLITAN DISTRICT

5972 County Road 234
Durango, CO 81301
Phone: 970-259-3102

2-24-2020

In regards to the fourth quarter TTHM violation of 2019

Dear Residents,

The Metro Districts first quarter TTHM (Total Tri Halo Methane) samples have come back from the lab and we are below the running annual average of 80 PPB (Parts per Billion). Our First quarter sample of 2020 came back as 29.6 PPB. Here is a snapshot of our current TTHM compliance values.

| | 1st Quarter Average | 2 nd Quarter Average | 3 rd Quarter Average | 4 th Quarter Average | TTHM Running average |
|----------------|---------------------|---------------------------------|---------------------------------|---------------------------------|----------------------|
| Results in PPB | 29.6 | 75.4 | 139 | 75.2 | 79.8 |
| Month sampled | Jan 2020 | April 2019 | July 2019 | October 2019 | |

Our next samples will be drawn the third week of April and with standard lab turn around we will have results in May and will post to our web site as well as report to the State. With the light winter we have had and the river maintaining flow throughout the year we expect that the organic carbon loading to be similar to years past.

We are hopeful that our priority 4 water case will come to completion this year. It will add 2/3 more water for our use from the river and allow for greater dilution when environmental events happen in our watershed. As always please feel free to contact me with questions or concerns at 970-946-8566 or email me at robert@edgemonranch.com

Thank you,
Robert Ludwig, ERMD Operator